

Daily Log Sheet for Pools and Hot Tubs

Test **each day** that the pool or hot tub is open. **Close the pool or hot tub** if the water tests above or below these ranges:

Disinfectant	Swimming pool	Hot tub
Chlorine	1.0 to 5.0 ppm	2.9 to 5.0 ppm
Bromine	1.0 to 5.0 ppm	2.0 to 5.0 ppm

- pH levels must be between 7.0 – 8.0
- Keep hot tub temperatures at 104°F or less.

Pool or Hot Tub Identifier: _____ Location: _____

[illegible]